

Message

From: Contreras, Peter [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=3C7E515833814B74A7EBAFCFEF8B6322-CONTRERAS, PETER]
Sent: 4/20/2020 10:45:25 PM
To: Kenknight, Jeff [Kenknight.Jeff@epa.gov]
Subject: Adam's initial review of PWS at Umatilla

Jeff – Here's Adam's review.. 2 systems exceeded 10 mg/L at the time:

- 1) An Oregon Fish Hatchery serving 18 people.
- 2) River Point Farms, serving 250 people.

Ex. 6 Personal Privacy (PP)

PWS Name	Population	Current Nitrate	Monitoring Date and Dates	ETT Score and Enforcement Status
Alive and Well	50	5.64 on 2/19	10.2 on 4/06	1
Bellinger Produce	100	4.76 on 1/20	50s, multiple samples in 10/19. Also history range from 20-28 in 11/18 and 1/19, 10/15, 3/14	0 – under an Admin Order for Nitrate MCL since 12/18. Will ask OHA for info on construction schedule and when expected to fall below MCL. Civil penalty due 2/4/20
Boardman, City of	3500	1.86 on 4/15	7.5 on 2/03	0
Comfort Inn Hermiston	100	No detect on 12/19	History of range from 7 to 12 from 5/15 back to 06	0
Lamb Weston	500	5.8 on 12/19	3 samples over 11 in 2019, before that in the 5 to 6 range back to '05	5 - for various M&R violations. Flag high samples with OHA.
Country Garden Estates MHP	175	9.8 on 12/00	5 to 6 back to '04	1
Hat Rock Mobile Court	60	ND on 11/19	10 on 4/06	0
Hat Rock Water Company	96	2.1 on 12/19	14 on 2/16 and 10 to 14 from 2014 to 2016.	6 for late reporting on Nitrate. Under a BCA in 2016 to construct Nitrate treatment.
Herrerias Park	20	5.7 on 12/19.	8.1 on 3/18. History between 4 and 8 going back to 2011	0
Irrigon, City of	1885	1.4 on 1/19	6 to 15 from 2008 back for shallow wells. Those were closed and fell to 1 or ND.	0
JR Simplot/ Calpine	22	2.7 on 12/19	9.9 on 8/19 and range from 2 to 9 going back to '04. Trend is up in the summer.	1. Flagg for OHA on trends up.

North Hill Water Corp	100	ND on 7/19	9 on 10/07	1
ODF/ WL irrigation Fish Hatchery	18	21.2 on 4/19	ND on 8/16 for new well that came on line 12/17, ranges from 6 to 21 on old well in '18 and '19.	2. Verify understanding with OHA if they are blending the wells.
OPRD Hat Rock State Park	500	4.6 on 9/19	19.4 on 1/18 with history between 4 and 15 going back to '11	0
Port of Morrow	1350	3.6 on 1/20	9.3 on 9/19. 10 on 9/09. Range from 3 to 9 going back to 06.	1
River Point Farms LLC	250	26 on 1/20	28 on 7/16. Range from 1 to 28 going back /04 with many over 10.	0 but with 20 points RTC'ed for Nitrate MCL in last two years. No enforcement. Will flag for OHA.
Short Stop #1	200	5.1 on 3/19	9.2 on 1/11. History between 4 and 9 going back to '07	1
Space Age Fuel	950	9.6 on 12/19	28 on 12/12. History on shallow well from 3 to 28 back to '03	0 but with 10 points RTC'ed for Nitrate MCL in '16. Will flag for OHA.
Sunridge Water Inc.	200	8.4 on 9/19	14 on 9/08. Range from 6 to 14 going back to '04	0
Upper Columbia Mill	70		14 on 4/15.	Inactive since 2016

Thanks,

Peter



Peter Contreras, Chief
Field, Data & Drinking Water Enforcement Section
Water Enforcement & Field Branch (20C-04)
Enforcement and Compliance Assurance Division
Seattle, WA (206) 553-6708